

Declaration of Conformity Revision	XE-DoC-EU-01
Supplier	Eurofyre Limited
Address	Unit C1 Knowle Village Business Park Mayles Lane Wickham Hampshire PO17 5DY United Kingdom

The supplier identified above herewith declares under its responsibility that the product covered by this declaration

System	Wi-Fyre Xenos, Operating Frequency Band: 868MHz; 916MHz
Part Number	Description
10-210	Wi-Fyre Xenos Wireless Optical Smoke Detector
10-226	Wi-Fyre Xenos Wireless Optical Smoke Detector, Black
10-211	Wi-Fyre Xenos Wireless Multi-Sensor Detector
10-227	Wi-Fyre Xenos Wireless Multi-Sensor Detector, Black
10-212	Wi-Fyre Xenos Wireless Heat Detector
10-228	Wi-Fyre Xenos Wireless Heat Detector, Black
10-213	Wi-Fyre Xenos Wireless Sounder Base
10-229	Wi-Fyre Xenos Wireless Sounder Base, Black
10-214	Wi-Fyre Xenos Wireless Sounder VAD Base, White Flash
10-230	Wi-Fyre Xenos Wireless Sounder VAD Base, Black, White Flash
10-215	Wi-Fyre Xenos Wireless Sounder VAD Base, Red Flash
10-216	Wi-Fyre Xenos Wireless Manual Call Point
10-218	Wi-Fyre Xenos Wireless Input Module
10-219	Wi-Fyre Xenos Wireless Output Module
10-222	Wi-Fyre Xenos Conventional Wall Sounder, White
10-225	Wi-Fyre Xenos Conventional Wall Sounder VAD, White

Part Number	Description
10-223	Wi-Fyre Xenos Conventional Wall Sounder VAD, White
10-200	Wi-Fyre Xenos Wireless Translator
10-203	Wi-Fyre Xenos Wireless Translator, Black
10-201	Wi-Fyre Xenos Wireless Expander
10-204	Wi-Fyre Xenos Wireless Expander, Black
10-202	Wi-Fyre Xenos Wireless Conventional Expander

Use for: **Fire Detection and Alarm System**

Is in conformity with the provisions of the following UK directive(s) (including all applicable amendments)

Reference	And that the technical / standards specifications indicated below have been applied:
2014/53/EU Directive RED	Spectrum EN 300 220-2 V3.1.1
	EMC EN 301 489-3 V2.1.1
	Safety EN 62368-1:2020/A11:2020
2014/30/EU Directive EMCD	EN 61000-6-3:2007 + A1:2011
	EN 50130-4:2011 + A1:2014
2014/35/EU Directive LVD	N/A
2011/65/EU Directive RoHS	EN IEC 63000:2018

Supplier has created the Technical Construction File, reference/number/directory:

\\SVRFS01\server_qualita_RESPONSABILE QUALITA___ENTI CERTIFICATORI-LABORATORI\IMQ\TEST REPORT\

The CE mark was first applied in: 2023



Signed on behalf of Eurofyre Limited

M. Redfearn

Mark Redfearn | General Manager | 15th January 2023