CERTIFICATE OF CONSTANCY OF PERFORMANCE

Certificate No.
0843-CPR-1338

Issue date
11-06-2024

Issue No.
1

Re-Issue date
N/A

This is to certify that UL International (UK) Ltd. did undertake the relevant AVCP procedures for the equipment identified below which was found to be in compliance with the Construction Products Regulation 2011 as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, subject to any conditions attached hereto.

Manufacturer: European Safety Systems Ltd

Address: Units 18 & 20, Impress House, Mansell Road Action, London W3 7QH, UK

Product: SONF1 Fire Alarm Device - Sounder

Places of production: Same as manufacturer

Harmonized Standard: EN 54-3:2001 + A1:2002 + A2:2006

Head of Approved Body:



Richard Bristow

Issued by UL International (UK) Ltd, Approved Body 0843.

UKAS PRODUCT CERTIFICATION
4705

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the above referenced standards, under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate will remain valid as long as neither the designated standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the UK Approved body.

UL Solutions
Form-ULID-006104 V8.0

UL International (UK) Limited
Unit 1-4 Horizon, Kingsland Business Park, Wade Rd.,
Basingstoke. RG24 8AH United Kingdom
© 2024 UL LLC. All rights reserved.

Detailed information sheet:

Product Reference:	Model SONF1DC024 Sounder
Type:	Type B (outdoor)
Description:	Model SONF1DC024 - Alarm Horn Sounder
Voltage:	24V dc (10-30V dc)
Certified Tones:	Tone 1: (Alternating Tone) 800/1000Hz @ 0.25s alternating Tone 2: (Rising Tone) 500/1200Hz @ 0.3Hz 0.5s Tone 3: (Fainting Tone) 1200/500Hz @ 1Hz Tone 4: (Alternating Tone) 544Hz(100mS)/440Hz (400mS) Tone 8: (Continuous Tone) 1000Hz Tone 9: (Continuous Tone) 544Hz
Accessories:	N/A
Identification and intended use	Product: Fire detection and fire alarm systems - Alarm devices - Sounders. Intended use: Fire safety

UL International (UK) Limited
Unit 1-4 Horizon, Kingsland Business Park, Wade Rd.,
Basingstoke. RG24 8AH United Kingdom

© 2024 UL LLC. All rights reserved.

Limitations on the acceptance or use of the product(s):

Installation instructions	To be used in accordance with the supplier's installation instructions, and technical datasheet.
Limitations	Only 24V dc version is certified.
UL Report:	S36282-D03-EuropeanDirective-Original

Terms and Conditions:

1. This certificate remains the property of UL International (UK) Ltd, herein "UL UK", and will be withdrawn if any conditions attached to its issue are not complied with.
2. This certificate is issued subject to the Global Services Agreement (GSA) and UKCA CPR Service Terms.
3. Production is limited to the site(s) as listed, or detailed within the Technical documentation held by UL UK.
4. Any product change, production/process changes, etc. which may affect conformity shall be notified to UL UK.
5. This certificate is only valid for placing goods on the market of United Kingdom excluding Northern Ireland.

END OF CERTIFICATE

UL International (UK) Limited
Unit 1-4 Horizon, Kingsland Business Park, Wade Rd.,
Basingstoke. RG24 8AH United Kingdom

© 2024 UL LLC. All rights reserved.